

**NOTICE OF CONCLUSION AND COMPLETION
REGARDING
CITY OF AURORA PUBLIC WATER SYSTEM
LEVEL 2 ASSESSMENT / REQUIRED CORRECTIVE ACTION**

The City of Aurora Public Water System triggered a Level 2 Assessment in January of 2020 due to the presence of total coliform bacteria within three (3) routine water samples, all samples were **negative** for E. coli bacteria. The assessment required a continuous disinfection of the system for 30 Days while maintaining a chlorine residual concentration of 0.20 mg/L at the furthest extremity of the system. The 30 Days of continuous disinfection began on January 18th, 2020 upon the initial confirmation of the .20 mg/L chlorine residual at the furthest extremity of the system. The City eliminated the addition of chlorine into the water system on February 16, 2020 following approval from DHHS representative. The average daily water use will eliminate any remaining chlorine residual from the water system.

We ask that the residents please notify the City of any standing water uncommon to current weather or any water percolating from the ground. Water leaks are a common source of total coliform bacteria within drinking water.

The City of Aurora Public Water System appreciates your patience and understanding as we work to maintain the highest water quality delivered to all our customers.

For further information or questions, residents and customers can contact City Hall at 402-694-6992.

Adam Darbro
Utility Superintendent